

**SOAH DOCKET NO. 473-21-0538
PUC DOCKET NO. 51415**

RECEIVED
2021 MAY 20 AM 10:04
PUBLIC UTILITY COMMISSION
FILING CLERK

**SOUTHWESTERN ELECTRIC POWER COMPANY'S RESPONSE
TO CITIES ADVOCATING REASONABLE DEREGULATION'S
FIRST SET OF REQUESTS FOR INFORMATION**

Question No. CARD 1-22:

Provide SWEPCO's annual SAIDI and SAIFI for the Company's Texas service area with and without major storms for each of the last four years and for the test year in this case.

Response No. CARD 1-22:

Please see CARD 1-22 Attachment 1 for SWEPCO's annual SAIDI and SAIFI for the Company's Texas service area with major storms. For SWEPCO's annual SAIDI and SAIFI for the Company's Texas service area without major storms, please see Schedule H-13.3.

Prepared By: Paul D. Flory

Title: Regulatory Consultant Sr

Sponsored By: Drew W. Seidel

Title: VP Dist Region Ops

SWEPCO TX, Data Includes Major Storms

| Year | State ID | SAIDI | SAIFI |
|-----------|----------|--------|-------|
| 2016 | TEXAS | 248.73 | 1.89 |
| 2017 | TEXAS | 746.43 | 2.14 |
| 2018 | TEXAS | 319.01 | 2.00 |
| 2019 | TEXAS | 781.05 | 2.45 |
| Test Year | TEXAS | 774.54 | 2.39 |